

Annual Technology Baseline



- About
- Technologies
 - Land-Based Wind
 - Offshore Wind
 - Distributed Wind
 - Utility-Scale PV
 - Commercial PV
 - Residential PV
 - Concentrating Solar Power
 - Geothermal
 - Hydropower
 - Utility-Scale PV-Plus-Battery
 - Utility-Scale Battery Storage
 - Commercial Battery Storage**
 - Residential Battery Storage
 - Pumped Storage Hydropower
 - Fossil Energy Technologies
 - Other Technologies (EIA)
- Data

Commercial Battery Storage


Parameter: (Multiple values) Scenario: (All)

Financials: (All) Market R&D

Cost Recovery Period: 30 years

Default Technology Detail: Commercial Battery Storage 4Hr

Technology Detail Filter: Default



data updated: 07/21/2022



ATB data for technologies on the website: <https://atb.nrel.gov/>

Parameter value projections by scenario, financial case, cost recovery period technological detail

Select the parameter (LCOE, CAPEX, Fixed O&M, Capacity Factor, and FCR [fixed charge rate]), financial case, cost recovery period, and technological detail. The year represents the commercial or R&D start year. The default technology detail best aligns with recent or anticipated near-term installations

The 2022 ATB represents cost and performance for battery storage across a range of durations (1–8 hours). It represents only lithium-ion batteries (LIBs)—with nickel manganese cobalt (NMC) and lithium iron phosphate (LFP) chemistries—at this time, with LFP becoming the primary chemistry for stationary storage starting in 2021. There are a variety of other commercial and emerging energy storage technologies; as costs are well characterized, they will be added to future editions of the ATB. There are a variety of other commercial and emerging energy storage technologies; as costs are well characterized, they will be added to future editions of the ATB.

The National Renewable Energy Laboratory's (NREL's) [Storage Futures Study](#) examined energy storage costs broadly and specifically the cost and performance of LIBs ([Augustine and Blair, 2021](#)). The costs presented here (and on the distributed [residential](#) storage and [utility-scale](#) storage pages) are an updated version based on this work. This work incorporates base year battery costs and breakdowns from ([Ramasamy et al., 2021](#)), which works from a bottom-up cost model. The bottom-up battery energy storage systems (BESS) model accounts for major components, including the LIB pack, inverter, and the balance of system (BOS) needed for the installation. However, we note that during the elapsed time between the calculations for the Storage Futures Study and the ATB release, updated values have been calculated as more underlying data have been collected. Though these changes are small, we recommend using the data presented here in the ATB rather than those previously published with the Storage Futures Study.

Base year costs for commercial and industrial BESS are based on NREL's bottom-up BESS cost model using the data and methodology of ([Ramasamy et al., 2021](#)), who estimated costs for a 600-kW_{DC} stand-alone BESS with 0.5–4.0 hours of storage. We use the same model and methodology but do not restrict the power or energy capacity of the BESS. ([Ramasamy et al., 2021](#)). assumed an

inverter/storage ratio of 1.67 based on guidance from [\(Denholm et al., 2017\)](#). We adopt this assumption, too.


Key modeling assumptions and inputs are shown in Table 1. Because we do not have battery costs that are specific to commercial and industrial BESS, we use the battery pack costs from [\(Ramasamy et al., 2021\)](#), which vary depending on the battery duration. These battery costs are close to our assumptions for battery pack costs for residential BESS at low storage durations and for utility-scale battery costs for utility-scale BESS at long durations. The underlying battery costs in [\(Ramasamy et al., 2021\)](#) come from [\(BNEF, 2019a\)](#) and should be consistent with battery cost assumptions for the residential and utility-scale markets.


Table 1. Commercial and Industrial LIB Energy Storage Systems: 2021 Cost Benchmark Model Inputs and Assumptions (2020 USD)

Model Component	Modeled Value	Description
System size	60–1,200 kW _{DC} power capacity 1-8 E/P ratio	Battery capacity is in kW _{DC} . E/P is battery energy to power ratio and is synonymous with storage duration in hours.
LIB price	1-hr: \$211/kWh 2-hr: \$168/kWh 4-hr: \$165/kWh 6-hr: \$144/kWh 8-hr: \$135/kWh	Ex-factory gate (first buyer) prices (Ramasamy et al., 2021) .
Inverter/storage ratio	1.67	Ratio of inverter power capacity to storage battery capacity (Denholm et al., 2017)
Battery central inverter price	\$75/kW	Ex-factory gate (first buyer) prices

We also consider the installation of commercial BESS systems at varying levels of duration (Figure 1). Costs come from NREL’s bottom-up PV cost model [\(Ramasamy et al., 2021\)](#). As shown, the cost per kilowatt-hour reduces dramatically with additional levels of duration. Therefore, accurately estimating the needed duration in commercial applications is critical to determining the total system cost.

Figure 1. Estimated costs of commercial stand-alone BESS using NREL bottom-up model (2021 benchmark data in 2020\$US)





Scenario Descriptions

Available cost data and projections for distributed battery storage are very limited. Therefore, the battery cost and performance projections in the 2022 ATB are based on the same literature review as the utility-scale and residential battery cost projections. The projections are based on a literature review of 19 sources published in 2018 or 2019, as described by [\(Cole and Frazier, 2020\)](#). Three projections from 2020 to 2050 are developed for scenario modeling based on this literature.

In all three of the scenarios described below, costs of battery storage are anticipated to continue to decline. The Storage Futures Study [\(Augustine and Blair, 2021\)](#) describes that the majority of this cost reduction comes from the battery pack cost component with minimal cost reductions in BOS, installation, and other components of the cost. The report indicates that NREL, BloombergNEF [\(BNEF\)](#), and others anticipate that the growth of the overall battery industry - across the consumer electronics sector, the transportation sector, and the electric utility sector - will lead to cost reductions. Additionally, BNEF and others indicate that changes in lithium-ion chemistry (such as switching away from cobalt) will also reduce cost. A third key factor is ongoing innovation with significant corporate and public research on batteries. Finally, the growth in the market (effective learning-by-doing) and more diversity of chemistries will expand and change the dynamics of the supply chain for batteries resulting in cheaper inputs to the battery pack [\(Mann et al., 2022\)](#).


- Conservative Technology Innovation Scenario (Conservative Scenario):** The conservative projection is comprised of the maximum projection in 2020, 2025, and 2030 among the 19 cost projections from the literature review. Defining the 2050 points is more challenging because only four data sets extend to 2050; they show cost reductions of 19%, 25%, 27%, and 39% from 2030 to 2050. The 25% is used for the Moderate and Conservative scenarios. In other words, the Conservative Scenario is assumed to decline by 25% from 2030 to 2050.
- Moderate Technology Innovation Scenario (Moderate Scenario):** The moderate projections are taken as the median point in 2020, 2025, and 2030 of the 19 projections reviewed. Defining the 2050 points is more challenging because only four data sets extend to 2050; they show cost reductions of 19%, 25%, 27%, and 39% from 2030 to 2050. The 25% is used for the Moderate and Conservative scenarios. In other words, the Moderate Scenario is assumed to decline by 25% from 2030 to 2050.
- Advanced Technology Innovation Scenario (Advanced Scenario):** The advanced projections are taken as the lowest cost point in 2020, 2025, and 2030 of the 19 projections reviewed. Defining the 2050 points is more challenging because only four data sets extend to 2050; they show cost reductions of 19%, 25%, 27%, and 39% from 2030 to 2050. The 39% is used for the Advanced Scenario. In other words, the Advanced Scenario is assumed to decline by 39% from 2030 to 2050.

Methodology

Future cost projections for commercial and industrial BESS and PV+BESS are made using the same methodology as is used for residential BESS and PV+BESS. The normalized cost reduction projections for LIB packs used in residential BESS by [\(Mongird et al., 2020\)](#) are applied to future battery costs, and cost reductions for other BESS components use the same cost reduction potentials in Figure 2. Costs for commercial and industrial PV systems come from the 2022 ATB Moderate and Advanced Scenarios. We could not find projected costs for commercial and industrial BESS in the literature for comparison.

Figure 2. Changes in projected component costs for

residential BESS (also used for commercial systems)




Data Source: (BNEF, 2019a)

Capital Expenditures (CAPEX)

Definition: The bottom-up cost model documented by (Ramasamy et al., 2021) contains detailed cost bins. Though the battery pack is a significant cost portion, it is not the majority of the cost of the battery system. This cost breakdown is different if the battery is part of a hybrid system with solar PV or a stand-alone system. These relative costs for commercial scale stand-alone battery are demonstrated in Table 2.

Figure 3. Cost Details for Commercial Building-Scale Battery Systems (600kW, 4 hour duration)



Capital costs by category. Hover over the bars or select items in the legend to see how cost components change for each scenario.

Select the arrow to see costs in a table instead of a graph.

[Go to table](#)



ATB data for technologies on the website: <https://atb.nrel.gov/>

Current Year (2021): The Current Year (2021) cost breakdown is taken from (Ramasamy et al., 2021) and is in 2020 USD.

Within the ATB Data spreadsheet, costs are separated into energy and power cost estimates, which allows capital costs to be constructed for durations other than 4 hours according to the following

equation:

$$\text{Total System Cost (\$/kW)} = (\text{Battery Pack Cost (\$/kWh)} \times \text{Storage Duration (kWh)} + \text{Battery Power Capacity (kW)} \times \text{BOS Cost (\$/kW)} + \text{Battery Power Constant (\$)}) / \text{Battery Power Capacity (kW)}$$

For more information about the power versus energy cost breakdown, see [\(Cole and Frazier, 2020\)](#).

For items included in CAPEX, see the table below.

Components of CAPEX

Balance of System Category	Balance of System
Electrical Infrastructure & Interconnection (electrical interconnection, electronic, electrical infrastructure, electrical)	Internal and control connections
	Power electronics
	Wiring and Conduits
	DC Cabling
	Inverter
	Switch Gear
	Transformers
	Energy Management System
Generation Equipment & Infrastructure (civil works, generation equipment, other equipment, support structure)	Monitors, Controls and Communications
	Plant construction
	Power plant equipment
	Battery Pack
	Battery Container
	Battery Management System
	Thermal Management System
	Fire Suppression System
	Battery Racking
Foundation for battery and inverters	
Installation & Indirect	Inverter Housing
	Distributable labor and materials
	Engineering
Owner's Costs	Start up and commissioning
	Development costs
	Environmental studies and permitting
	Insurance costs
	Legal fees
	Preliminary feasibility and engineering studies

■ All Technologies
■ Commercial Battery Storage

Inclusions in CAPEX
 Technology-specific items are shown in orange, and items included for all technologies projected in the ATB are shown in blue.


ATB data for technologies on the website:

Future Projections: Future projections are based on the same literature review data that inform [\(Cole and Frazier, 2020\)](#), which generally used the median of published cost estimates to develop a Mid Technology Cost Scenario and the minimum values to develop a Low Technology Cost Scenario. However, as the battery pack cost is anticipated to fall more quickly than the other cost components (which is similar to the recent history of PV system costs), the battery pack cost reduction is taken from [\(BNEF, 2019b\)\(Frith, 2020\)](#) and is reduced more quickly. This tends to make the longer-duration batteries (e.g., 8 hours) decrease more quickly while shorter-duration batteries (e.g., 2 hours) decrease less quickly into the future. All durations trend toward a common trajectory as battery pack costs decrease into the future.

Operation and Maintenance (O&M) Costs

Base Year: [\(Cole et al., 2021\)](#) assume no variable O&M (VOM) costs . All operating costs are instead represented using fixed O&M (FOM) costs. The fixed O&M costs include battery replacement costs, based on assumed battery degradation rates that drive the need for 20% capacity augmentations after 10 and 20 years to return the system to its nameplate capacity [\(Ramasamy et al., 2021\)](#). The augmentations assume that 20% of the cells are replaced in each augmentation, with costs for battery cells and bidirectional inverters dropping 40% in the next 20 years. In the 2022 ATB, FOM is defined as the value needed to compensate for degradation to enable the battery system to have a constant capacity throughout its life. According to the literature review [\(Cole et al., 2021\)](#), FOM costs are estimated at 2.5% of the capital costs in dollars per kilowatt. Items included in O&M are shown in the table below.

Components of O&M Costs

Fixed Costs	Administrative fees
	Administrative labor
	Insurance
	Legal fees
	Operating labor
	Other
	Property taxes
	Site security
	Taxes
Fixed Costs Component	Project management
Maintenance	General maintenance
	Scheduled maintenance over technical life
	Unscheduled maintenance over technical life
Replacement Costs	Annualized present value of large component replacement over ..

■ All Technologies

Inclusions in O&M

Technology-specific items are shown in orange, and items included for all technologies projected in the ATB are shown in blue.



ATB data for technologies on the website: [https://atb.nrel.gov/](#)

Future Years: In the 2022 ATB, the FOM costs and the VOM costs remain constant at the values listed above for all scenarios.

Capacity Factor

The cost and performance of the battery systems are based on an assumption of approximately one cycle per day. Therefore, a 4-hour device has an expected capacity factor of 16.7% ($4/24 = 0.167$), and a 2-hour device has an expected capacity factor of 8.3% ($2/24 = 0.083$). Degradation is a function of this usage rate of the model and systems might need to be replaced at some point during the analysis period. We use the capacity factor for a 4-hour device as the default value for ATB.

Round-Trip Efficiency

Round-trip efficiency is the ratio of useful energy output to useful energy input. (Mongird et al., 2020) identified 86% as a representative round-trip efficiency, and the 2022 ATB adopts this value. In the same report, testing showed 83-87%, literature range of 77-98%, and a projected increase to 88% in 2030.

References

The following references are specific to this page; for all references in this ATB, see [References](#).

Augustine, Chad, and Nate Blair. "Energy Storage Futures Study: Storage Technology Modeling Input Data Report." Golden, CO: National Renewable Energy Laboratory, 2021. <https://www.nrel.gov/docs/fy21osti/78694.pdf>

Ramasamy, Vignesh, David Feldman, Jal Desai, and Robert Margolis. "U.S. Solar Photovoltaic System and Energy Storage Cost Benchmarks: Q1 2021." Golden, CO: National Renewable Energy Laboratory, 2021. <https://www.nrel.gov/docs/fy22osti/80694.pdf>

Denholm, Paul, Josh Eichman, and Robert Margolis. "Evaluating the Technical and Economic Performance of PV Plus Storage Power Plants." Golden, CO: National Renewable Energy Laboratory, 2017. <https://www.nrel.gov/docs/fy17osti/68737.pdf>

BNEF. "Energy Storage System Costs Survey 2019." BloombergNEF, October 14, 2019a.

Mann, Margaret, Vicky Putsche, and Benjamin Sharger. "Grid Energy Storage: Supply Chain Deep Dive Assessment." Washington, D.C.: U.S. Department of Energy, February 24, 2022. <https://www.energy.gov/policy/securing-americas-clean-energy-supply-chain>

Cole, Wesley, and Will A. Frazier. "Cost Projections for Utility-Scale Battery Storage: 2020 Update." Technical Report. Golden, CO: National Renewable Energy Laboratory, 2020. <https://www.nrel.gov/docs/fy20osti/75385.pdf>

Mongird, Kendall, Vilayanur Viswanathan, Jan Alam, Charlie Vartanian, Vincent Sprengle, and Richard Baxter. "2020 Grid Energy Storage Technology Cost and Performance Assessment." Washington, D.C.: U. S. Department of Energy, December 2020. <https://www.energy.gov/energy-storage-grand-challenge/downloads/2020-grid-energy-storage-technology-cost-and-performance>.

BNEF. "2019 Long-Term Energy Storage Outlook." BloombergNEF, July 31, 2019b. <https://www.bnef.com/core/insights/21113>.

Frith, James. "Energy Storage System Costs Survey 2020." Bloomberg New Energy Finance, December 16, 2020.

Cole, Wesley, Will A. Frazier, and Chad Augustine. "Cost Projections for Utility-Scale Battery Storage: 2021 Update." Technical Report. Golden, CO: National Renewable Energy Laboratory, 2021. <https://www.nrel.gov/docs/fy21osti/79236.pdf>

Developed with funding from the U.S. Department of Energy's Office of Energy Efficiency and Renewable Energy.

National Renewable Energy Laboratory

[About](#)

[Research](#)

[Work With Us](#)

[News](#)

[Careers](#)

[Contact Us](#)

[Visit](#)

[Subscribe to NREL](#)



[Accessibility](#)

[Disclaimer](#)

[Security and Privacy](#)

[Site Feedback](#)

[Developers](#)

[Employees](#)



The National Renewable Energy Laboratory is a national laboratory of the [U.S. Department of Energy](#), Office of Energy Efficiency and Renewable Energy, operated by the [Alliance for Sustainable Energy LLC](#).